

Total Coliform and Heterotrophic Plate Count Results :
 Summary of Samples Collected: July 1998 to June 1999

Site	Total Coliforms (N/100 mL)					Heterotrophic Plate Count @ 35°C			
	Guideline Values ^D	No of Samples	Max	Min	Median	No of Samples	Max	Min	Median
Te Marua Pumping Station	0	361	0	0	0	262	>5700	0	0
Stokes Valley Charthouse	0	210	0	0	0	52	>5700	0	0
Paremata/Plimmerton	0	208	0	0	0	51	1200	0	0
Johnsonville Pumping Station	0	209	0	0	0	51	>5700	0	0
Karori (end of Kaitoke main)	0	208	0	0	0	52	>5700	0	0
Wainuiomata Treatment Plan Gatehouse	0	299	0	0	0	49	>5700	0	1
Hutt Park Bridge	0	209	0	0	0	52	>5700	0	1
Thorndon Pumping Station	0	209	0	0	0	52	>5700	0	0
Waterloo Treatment Plan	0	269	0	0	0	259	>5700	0	2
Buick Street	0	263	0	0	0	263	>5700	0	1
Gear Island	0	258	0	0	0	258	>5700	0	1

^D Drinking-water Standards for New Zealand (1995). Please note: there are no guidelines values for Heterotrophic Plate Count.