



COPY

13 January 2010

Petone Pure Water Company Limited
PO Box 208
Wellington 6140

For: Barry Wilson

Compliance monitoring report 2008/2009 for WGN040360 [23776]

<i>Consent holder:</i>	<i>Petone Pure Water Company Limited</i>
<i>Description:</i>	<i>To take and use water from the Waiwhetu Artesian Aquifer.</i>
<i>Location:</i>	<i>Gear Island, Jackson Street, Petone</i>
<i>Consent type:</i>	<i>Water permit</i>

Thank you for meeting me and for your assistance during my inspection of your water permit on 9 June 2009.

Annual compliance rating

WGN040360 [23776] is rated as **partially complying** for the 2008/2009 compliance year as Condition 3 of your consent was not complied with.

Compliance ratings are explained overleaf.

As outlined by Condition 2 your rate of abstraction did not exceed 350 cubic metres over any seven day period during the 2008/2009 compliance year.

The majority of your meter and abstraction records sent to Greater Wellington (GW) in the 2008/2009 compliance year was done so on a monthly basis. However, the records for the months of December and for the months of February to June were not submitted to GW on a monthly basis in accordance with condition 3 of your resource consent which states:

The permit holder shall meter all abstractions and supply records of total daily abstraction to the Manager, Consents Management, Wellington Regional Council, on a monthly basis. The installed meter shall have an accuracy of +/- 5%.

The records for December were received by GW on 2 February 2009 (1 month late), whilst the records for the months of February to June were not physically received by GW and confirmation that no abstraction occurred in these months was received during my inspection of your site on 9 June 2009.

As I outlined to you on site even if no abstraction has occurred please still submit monthly records or send GW an email to confirm that no abstraction has occurred. If it is easier your meter and abstraction records can be emailed to notifications@gw.govt.nz. Please include the consent reference and the name and phone number of a contact person responsible for the take.

Action required by consent holder


Please continue to comply with consent conditions, particularly condition 3 which requires you to submit abstraction records to GW on a monthly basis, please include months where no abstraction has occurred at the plant.

As outlined on site, please inform GW if you relocate the plant from the Unilever site. Once you have the location of the new premises in mind please contact GW so that we can inform you of any consenting requirements.

Further assessments

As your consent is for an on-going activity another inspection will be made in the 2009/2010 compliance year. You will be contacted closer to the time to arrange a suitable time to visit.

If you have any questions about the monitoring of your consent or your compliance assessment report please contact me on 802 0335.



Amy Holden
Resource Advisor, Environmental Regulation

Annual compliance ratings:

These are based on the financial year, i.e., from 1 July to 30 June. Your annual compliance rating will be reported in the *Greater Wellington annual compliance report* which, after being presented to Greater Wellington's Environment Committee, becomes available to the public.

<i>Fully complying</i>	100 % compliance with all consent conditions at all times.
<i>Mainly complying</i>	Compliance with all conditions relating to environmental effects during the year. However, there may be minor non-compliance with administrative-type conditions, e.g., late (but by no more than one month) submission of management reports. All administrative conditions are met at the end of the financial year.
<i>Partially complying</i>	Compliance with all conditions relating to environmental effects during the year. However, there may be non-compliance with administrative-type conditions, e.g., late submission of management reports. The consent holder needs to be prompted by Wellington Regional Council before such administrative conditions are met at the end of the financial year.
<i>Non-complying</i>	Non-compliance with condition(s) relating to environmental effects during the financial year (this includes any confirmed complaints) and/or not all administrative-type conditions met at the end of the financial year.



FILE NOTE

DATE 6 January 2010
AUTHOR Amy Holden
SUBJECT FILE NOTE - Calculation of usage for 2008/2009 Compliance year
FILE NUMBER WGN/04/0360/1

Assessment of water usage for Water Permit WGN040360 – Petone Pure Water

Condition 2 of consent allows the permit holder to take – *The rate of abstraction shall not exceed 350 cubic metres over any seven day period.*

Total monthly use for the respective months was:

July – 44,921 litres (44.92m ³)	received 11 August 2008
Aug– 47,151 litres (47.15m ³)	received 4 September 2008
Sep – 36,997 litres (37.0m ³)	received 13 October 2008
Oct– 0 litres (0m ³)	received 3 November 2008
Nov – 43,251 litres (43.25m ³)	received 1 December 2008
Dec – 65,132 litres (65.13m ³)	received 2 February 2009 (late by 1 month)
Jan – 87,928 litres (87.93m ³)	received 2 February 2009
Feb – 0 litres (0m ³)	No records sent in but confirmed at site visit on 9 June 2009 that they currently are not abstracting hence no records.
March – 0 litres (0m ³)	
April - 0 litres (0m ³)	
May – 0 litres (0m ³)	
June – 0 litres (0m ³)	

Yearly Total – 325,380 litres (325.38m³)

The rate of take did not exceed 350 cubic metres over any seven day period during the 2008/2009 compliance year.

Condition 3 of consent states - *The permit holder shall meter all abstractions and supply records of total daily abstraction to the Manager, Consents Management, Wellington Regional Council, on a monthly basis. The installed meter shall have an accuracy of +/- 5%.*

However, the meter and abstraction records for the months of December and February to June were not submitted to GW on a monthly basis in accordance with condition 3. The meter and abstraction records for December were received by GW on the 2 February 2009 (1 month late), whilst the meter and abstraction records for February to June have not been received by GW. However, as Barry Wilson confirmed on 9 June 2009 during the site visit the plant is currently not bottling any water hence they have not sent in any abstraction records. As I outlined to Barry on site even if they are not taking water they should still send GW a record or an email to saying that no abstraction has occurred. I will note this in the compliance report. Therefore, the permit holder is only **partially complying** with their resource consent the 2008/2009 compliance year as there abstraction records a late by more than one month.

Amy Holden



FILE NOTE

DATE 5 January 2010
AUTHOR Amy Holden
SUBJECT FILE NOTE - 2008/2009 Compliance inspection 9 June 2009 WGN040360
FILE NUMBER WGN/04/0360/1

On the 9 June 2009 I undertook the 2008/2009 compliance inspection of Water permit WGN040360 with Barry Wilson of Petone Pure Water Company. I arrived at Unilever at 9.40am and showed my warrant.

Barry outlined that they currently are not abstracting water at the moment. He has sent in the previous water use records. Barry outlined that he has not sent any more records in as have not been using. I outlined to Barry even if not using he should send as an email saying that no abstraction had occurred.

Barry showed me around the plant of where water enters the factory and gets oxidised and then enters the bottling process. The water take is used for water and the sterilising the bottles.

Barry showed me the location of the where the bore water enters into the plant from outside and the location of the bore. The bore is located over the other side of the stream (dead arm) next to the vintage car club. It is in a tin box and is padlocked shut.

Barry outlined that they might be looking at relocating the factory to another site as lease at Unilever finished in 3 months. I told Barry to inform us if changes to the plant location occur and we can then determine what consenting requirements might be required. I told Barry this would not be too much of an issue if the location was within the Lower Hutt groundwater zone. He just needs to inform greater wellington and to transfer his water permit to the new site.

Left site at 9.50 and I took all photos whilst on site.

Amy Holden



Location of bore is across the dead arm stream in tin box next to vintage car club.



Location of bore is across the dead arm stream in tin box in centre of this picture



Looking back across from bore towards factory located in Unilever's property



Location of where bore water enters into factory on south east corner of the factory building.

Water take compliance inspection sheet

Consent number:	<u>WGT040360</u>	Coco Id:	<u>23776</u>
Consent holder:	<u>Petone Pure water Company Limited</u>		
Consent holder contact details:	<u>Barry Wilson</u>		
Email address:	<u>021 470 467</u>		
Water take address:	<u>Geor Island Jackson Street</u>		
Inspection date:	<u>9.6.09</u>	Time:	<u>On site: 9.40 Left Site: 9.50</u>
Officer:	<u>Amy Holden</u>		
Warrant shown:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No:	
		If No, Why?	<u></u>
GPS	<u></u>		
Water meter reading:	<u></u>		
<small>(note: units the meter is recorded in etc litres/second, m³)</small>			
Photo of meter reading and bore taken:	<input checked="" type="checkbox"/> Yes		
Serial number:	<u>-</u> <i>↳ no photo of meter as currently not obstructing. Meter located across stream near utility car club, photo of surface of bore taken</i>		
Pump make and model:	<u>-</u>		
Serial number:	<u>-</u>		
Estimated rate of abstraction:	<u>-</u>		

WGN040360

#651229

Amy Holden

From: Amy Holden
Sent: Friday, 5 June 2009 4:29 p.m.
To: [REDACTED]
Subject: 2008/2009 compliance visit for WGN040360

Hi Barry

Just confirming the details of next weeks inspection of Petone Pure Water Company's consent WGN040360.

I will meet you at the site at **9.45am on the 9th June 2009.**

Regards

Amy Holden

Resource Advisor
Environmental Regulation
Greater Wellington Regional Council
P O Box 11-646
142 Wakefield Street
Wellington
New Zealand
DDI: 04 802 0335
Fax: 04 385 6960
Website: www.gw.govt.nz

WGN040360

Amy Holden

#650077

From: System Administrator
To: [REDACTED]
Sent: Wednesday, 3 June 2009 12:48 p.m.
Subject: Undeliverable: 2008/2009 compliance visit for WGN040360

Your message did not reach some or all of the intended recipients.

Subject: 2008/2009 compliance visit for WGN040360
Sent: 2/06/2009 4:34 p.m.

The following recipient(s) could not be reached:

[REDACTED] on 2/06/2009 4:35 p.m.

The e-mail system was unable to deliver the message, but did not report a specific reason. Check the address and try again. If it still fails, contact your system administrator.

< wrcipgw.wrc.govt.nz #5.0.0 X-Firewall-Mailer-Daemon; Name service error for name=petonepure.co.nz type=A: Host not found >

Amy Holden

#649728

From: Amy Holden
Sent: Tuesday, 2 June 2009 4:34 p.m.
To: [REDACTED]
Subject: 2008/2009 compliance visit for WGN040360

Hi Andrew

I want to come and inspect your resource consent WGN040360, which authorises the abstraction of groundwater from the Waiwhetu Artesian Aquifer.

I was hoping to come and inspect this consent on the **9th June 2009** at around **9.00am**.

If you could let me know if this time and date suits that would be great.

I tried ringing the number Greater Wellington has for this consent (568 7886) but this seemed like it was no longer connected. If you have a new contact number we are able to get hold of you on this would be great.

Regards

Amy Holden

Resource Advisor
Environmental Regulation
Greater Wellington Regional Council
P O Box 11-646
142 Wakefield Street
Wellington
New Zealand
DDI: 04 802 0335
Fax: 04 385 6960
Website: www.gw.govt.nz

Amy Holden

From: Nicola Widdis
Sent: Monday, 2 February 2009 9:18 a.m.
To: Amy Holden
Cc: Alistair Cross
Subject: Petone Pure Water - Daily abstraction readings for - December 2008 & January 2009

Attachments: WGN_DOCS-607344.PDF.DRF



WGN_DOCS-60734
4.PDF.DRF (4 KB)...

Petone Pure Water Standard Form

Reference Number: PP-FR-016
Title: Abstraction Record
Prepared By: Andrew Torrance
Location: Petone Pure Water Plant
Date: 7 April, 2008

.....
To: Greater Wellington Resource Consents Management Fax 3856960

From: Petone Pure Water Co Ltd.

Daily Abstraction on a monthly basis.

Month *December* Year *2008*

Equipment

GF Signet transmitter model 8550 integral mounted to GF Signet sensor 3-8510
 Flow meter installed April 2005

Total Litres at start of month 2243753

Day	Daily litres	Total litres	Day	Daily litres	Total litres
1			17	21832	
2			18	16854	
3			19		
4			20		
5			21		
6			22		
7			23		
8			24		
9	26446		25		
10			26		
11			27		
12			28		
13			29		
14			30		
15			31		
16					

Total seven day abstraction 1-7 _____

Total seven day abstraction 8-15 _____

Total seven day abstraction 16-23 _____

Total seven day abstraction 24-31 _____

Total time on bypass _____ = _____

Flow rate on bypass 2litres/m _____

Total Month 65132

2308885

Sign off Manager _____

Petone Pure Water Standard Form

Reference Number: PP-FR-016
 Title: Abstraction Record
 Prepared By: Andrew Torrance
 Location: Petone Pure Water Plant
 Date: 7 April, 2008

.....
To: Greater Wellington Resource Consents Management Fax 3856960
 From: Petone Pure Water Co Ltd.
 Daily Abstraction on a monthly basis.
 Month January Year 2009.
Equipment
 GF Signet transmitter model 8550 integral mounted to GF Signet sensor 3-8510
 Flow meter installed April 2005

Total Litres at start of month 2308885.

Day	Daily litres	Total litres	Day	Daily litres	Total litres
1			17		
2			18		
3			19		
4			20		
5	<u>21657</u>		21		
6	<u>21928</u>		22		
7	<u>15408</u>		23		
8	<u>18935</u>		24		
9			25		
10			26		
11			27		
12			28		
13			29		
14			30		
15			31		
16					

Total seven day abstraction 1-7 68993
 Total seven day abstraction 8-15 18935
 Total seven day abstraction 16-23 _____
 Total seven day abstraction 24-31 _____
 Total time on bypass _____ = _____
 Flow rate on bypass 2litres/m _____
 Total Month 87928

Sign off Manager _____

2396813?

WGN040360

W593378

Amy Holden

From: Alistair Cross
Sent: Monday, 1 December 2008 2:39 p.m.
To: Amy Holden
Subject: FW: Daily Abstration Return - November 2008 (WGN040360)
Attachments: WGN_DOCS-593378.PDF.DRF

From: Ted Stasiewicz
Sent: Monday, 1 December 2008 1:20 p.m.
To: Alistair Cross
Subject: Daily Abstration Return - November 2008 (WGN040360)



WGN_DOCS-59337
8.PDF.DRF (4 KB)...

Petone Pure Water Standard Form

Reference Number: **PP-FR-016**
 Title: **Abstraction Record**
 Prepared By: **Andrew Torrance**
 Location: **Petone Pure Water Plant**
 Date: **7 April, 2008**

.....
To: Greater Wellington Resource Consents Management Fax 3856960
 From: **Petone Pure Water Co Ltd.**
 Daily Abstraction on a monthly basis.
 Month November Year 2008
Equipment
 GF Signet transmitter model 8550 integral mounted to GF Signet sensor 3-8510
 Flow meter installed April 2005

Total Litres at start of month 2200502.

Day	Daily litres	Total litres	Day	Daily litres	Total litres
1			17		
2			18		
3			19		
4			20		
5			21		
6			22		
7			23		
8			24		
9			25	16970	2217472
10			26		
11			27	26281	2243753
12			28		
13			29		
14			30		
15			31		
16					

Total seven day abstraction 1-7 NIL
 Total seven day abstraction 8-15 NIL
 Total seven day abstraction 16-23 NIL
 Total seven day abstraction 24-31 43251
 Total time on bypass = NIL
 Flow rate on bypass 2litres/m
 Total Month 43251

Sign off Manager

Andrew Torrance

wgn/04/0360

Amy Holden

From: Nicola Widdis
Sent: Monday, 3 November 2008 3:47 p.m.
To: Amy Holden
Cc: Alistair Cross
Subject: Petone Pure Water - Daily abstraction readings for October 2008

Attachments: WGN_DOCS-583985.PDF.DRF



WGN_DOCS-58398
5.PDF.DRF (4 KB)...

Petone Pure Water Standard Form

Reference Number: **PP-FR-016**
 Title: **Abstraction Record**
 Prepared By: **Andrew Torrance**
 Location: **Petone Pure Water Plant**
 Date: **7 April, 2008**

.....
 To: **Greater Wellington Resource Consents Management Fax 3856960**

From: **Petone Pure Water Co Ltd.**

Daily Abstraction on a monthly basis.

Month October Year 2008

Equipment

GF Signet transmitter model 8550 integral mounted to GF Signet sensor 3-8510
 Flow meter installed April 2005

Total Litres at start of month 2200502

Day	Daily litres	Total litres	Day	Daily litres	Total litres
1			17		
2			18		
3			19		
4			20		
5			21		
6			22		
7			23		
8			24		
9			25		
10			26		
11			27		
12			28		
13			29		
14			30		
15			31		
16					

Total seven day abstraction 1-7 _____
 Total seven day abstraction 8-15 _____
 Total seven day abstraction 16-23 _____
 Total seven day abstraction 24-31 _____
 Total time on bypass _____ = _____
 Flow rate on bypass 2litres/m _____
 Total Month NIL

Sign off Manager _____

wgn040360

577175

Amy Holden

From: Nicola Widdis
Sent: Monday, 13 October 2008 11:48 a.m.
To: Amy Holden
Cc: Alistair Cross
Subject: Petone Pure Water - Daily abstraction readings for September 2008

Attachments: WGN_DOCS-577175.PDF.DRF



WGN_DOCS-57717
5.PDF.DRF (4 KB)...

Petone Pure Water Standard Form

Reference Number: **PP-FR-016**
 Title: **Abstraction Record**
 Prepared By: **Andrew Torrance**
 Location: **Petone Pure Water Plant**
 Date: **7 April, 2008**

.....
To: Greater Wellington Resource Consents Management Fax 3856960

From: **Petone Pure Water Co Ltd.**

Daily Abstraction on a monthly basis.

Month September Year 2008

Equipment

GF Signet transmitter model 8550 integral mounted to GF Signet sensor 3-8510
 Flow meter installed April 2005

Total Litres at start of month 2163505

Day	Daily litres	Total litres	Day	Daily litres	Total litres
1			17		
2			18		
3			19		
4			20		
5			21		
6			22		
7			23		
8			24		
9			25	13076	2176381
10			26	18295	2194676
11			27		
12			28		
13			29	5826	2200502
14			30		
15			31		
16					

Total seven day abstraction 1-7 _____

Total seven day abstraction 8-15 _____

Total seven day abstraction 16-23 _____

Total seven day abstraction 24-31 _____

Total time on bypass _____ =

Flow rate on bypass 2litres/m _____

Total Month _____

37197

NIL

37197

Torrance

Sign off Manager



16 September 2008

Petone Pure Water Company Limited
PO Box 208
Wellington 6140

COPY

For: Andrew Torrance

Compliance monitoring report 2007/2008 for WGN040360 [23776]

<i>Consent holder:</i>	<i>Petone Pure Water Company Limited</i>
<i>Description:</i>	<i>To take and use water from the Waiwhetu Artesian Aquifer.</i>
<i>Location:</i>	<i>Gear Island, Jackson Street, Petone</i>
<i>Consent type:</i>	<i>Water permits</i>

Thank you for your assistance during my inspection on the 26th of May 2008.

Annual compliance rating

WGN040360 [23776] is rated as *fully complying* for the 2007/2008 compliance year.

Action required by consent holder

Please continue to comply with your consent conditions, particularly condition 3 which requires your abstraction records to be submitted to Greater Wellington Regional Council.

Further assessments

As your consent is for an on-going activity another inspection will be made in 12 months time. You will be contacted closer to the time to arrange a suitable time to visit.

If you have any questions about the monitoring of your consent or your compliance assessment report please contact Amy Holden on 802 0335.

John Ballinger

Administrative Assistant, Environmental Regulation

Date: 16 September 2008

Annual compliance ratings:

These are based on the financial year, i.e., from 1 July to 30 June. Your annual compliance rating will be reported in the *Greater Wellington annual compliance report* which, after being presented to Greater Wellington's Environment Committee, becomes available to the public.

<i>Fully complying</i>	100 % compliance with all consent conditions at all times.
<i>Mainly complying</i>	Compliance with all conditions relating to environmental effects during the year. However, there may be minor non-compliance with administrative-type conditions, e.g., late (but by no more than one month) submission of management reports. All administrative conditions are met at the end of the financial year.
<i>Partially complying</i>	Compliance with all conditions relating to environmental effects during the year. However, there may be non-compliance with administrative-type conditions, e.g., late submission of management reports. The consent holder needs to be prompted by Wellington Regional Council before such administrative conditions are met at the end of the financial year.
<i>Non-complying</i>	Non-compliance with condition(s) relating to environmental effects during the financial year (this includes any confirmed complaints) and/or not all administrative-type conditions met at the end of the financial year.



FILE NOTE

DATE 16 September 2008
AUTHOR Richard Taylor
SUBJECT 2007/08 compliance inspection
FILE NUMBER WGN/04/0360/1

Carried out compliance inspection at Petone Pure on 26/05/08 and met with Andrew on site. All in good condition and there were no obvious leaks, though some maintenance will be required in future to replace the pipe from the bore head to the production line. Abstraction records have been sent in.

Fully complying at time of inspection.

Richard Taylor

Amy Holden

From: Nicola Widdis
Sent: Thursday, 4 September 2008 09:29 a.m.
To: Amy Holden
Cc: Alistair Cross
Subject: Petone Pure Water - Daily abstraction readings for August 2008

Attachments: WGN_DOCS-566060.PDF.DRF



WGN_DOCS-56606
0.PDF.DRF (4 KB)...

Petone Pure Water Standard Form

Reference Number: **PP-FR-016**
 Title: **Abstraction Record**
 Prepared By: **Andrew Torrance**
 Location: **Petone Pure Water Plant**
 Date: **7 April, 2008**

.....
To: Greater Wellington Resource Consents Management Fax 3856960
 From: **Petone Pure Water Co Ltd.**
 Daily Abstraction on a monthly basis.
 Month *August* Year *2008*
Equipment
 GF Signet transmitter model 8550 integral mounted to GF Signet sensor 3-8510
 Flow meter installed April 2005

Total Litres at start of month 2110354

Day	Daily litres	Total litres	Day	Daily litres	Total litres
1			17		
2			18		
3			19		
4			20		
5			21		
6			22		
7			23		
8			24		
9			25		
10			26	15394	2131748
11			27	13195	2144943
12			28	18562	2163505
13			29		
14			30		
15			31		
16					

Total seven day abstraction 1-7
 Total seven day abstraction 8-15
 Total seven day abstraction 16-23
 Total seven day abstraction 24-31
 Total time on bypass =
 Flow rate on bypass 2litres/m
 Total Month

0
0
0
47151
NIL
47151
Handwritten signature

Sign off Manager

wgn042360

559896

Amy Holden

From: Alistair Cross
Sent: Monday, 11 August 2008 12:06 p.m.
To: Amy Holden
Subject: FW: Petone Pure Water - Daily abstraction readings for July 2008
Attachments: WGN_DOCS-559896.PDF

From: Nicola Widdis
Sent: Monday, 11 August 2008 12:04 p.m.
To: Alistair Cross
Subject: Petone Pure Water - Daily abstraction readings for July 2008



WGN_DOCS-#5598
v1-Petone_Pur...

Petone Pure Water Standard Form

Reference Number: **PP-FR-016**
 Title: **Abstraction Record**
 Prepared By: **Andrew Torrance**
 Location: **Petone Pure Water Plant**
 Date: **7 April, 2008**

.....
To: Greater Wellington Resource Consents Management Fax 3856960

From: **Petone Pure Water Co Ltd.**

Daily Abstraction on a monthly basis.

Month July Year 2008

Equipment:

GF Signet transmitter model 8550 integral mounted to GF Signet sensor 3-8510
 Flow meter installed April 2005

Total Litres at start of month 2071433

Day	Daily litres	Total litres	Day	Daily litres	Total litres
1			17		
2			18		
3			19		
4			20		
5			21		
6			22		
7			23		
8			24	14520	2085953
9			25	14532	2100485
10			26		
11			27		
12			28	15869	2116354
13			29		
14			30		
15			31		
16					

Total seven day abstraction 1-7 NIL
 Total seven day abstraction 8-15 NIL
 Total seven day abstraction 16-23 NIL
 Total seven day abstraction 24-31 44921
 Total time on bypass = NIL
 Flow rate on bypass 2litres/m
 Total Month 44921

Sign off Manager Starrum

ugh040360/1

#551436

Amy Holden

From: Belinda Krimp
Sent: Wednesday, 16 July 2008 09:50 a.m.
To: Amy Holden
Subject: FW: Petone Pure Water - Daily abstraction readings for June 2008

Attachments: WGN_DOCS-551436.PDF.DRF

From: Nicola Widdis
Sent: Wednesday, 16 July 2008 09:31 a.m.
To: Belinda Krimp
Cc: Alistair Cross
Subject: Petone Pure Water - Daily abstraction readings for June 2008



WGN_DOCS-55143
F.DRF (4 KB)...

Petone Pure Water Standard Form

Reference Number: **PP-FR-016**
 Title: **Abstraction Record**
 Prepared By: **Andrew Torrance**
 Location: **Petone Pure Water Plant**
 Date: **7 April, 2008**

To: **Greater Wellington Resource Consents Management Fax 3856960**

From: **Petone Pure Water Co Ltd.**

Daily Abstraction on a monthly basis.

Month June Year 2008

Equipment

GF Signet transmitter model 8550 integral mounted to GF Signet sensor 3-8510
 Flow meter installed April 2005

Total Litres at start of month 2067596

Day	Daily litres	Total litres	Day	Daily litres	Total litres
1			17		
2			18		
3			19		
4			20		
5			21		
6			22		
7			23		
8			24		
9			25		
10			26	3837	2071433
11			27		
12			28		
13			29		
14			30		
15			31		
16					

Total seven day abstraction 1-7

Total seven day abstraction 8-15

Total seven day abstraction 16-23

Total seven day abstraction 24-31

Total time on bypass =

Flow rate on bypass 2litres/m

Total Month

0
0
0
3837
NIL
3837

Sign off Manager

Asram

Amy Holden

From: Belinda Krimp
Sent: Wednesday, 11 June 2008 11:05 a.m.
To: Amy Holden
Cc: Alistair Cross
Subject: FW: Petone Pure Water - Daily abstraction readings for May 2008

Attachments: WGN_DOCS-542157.PDF.DRF

FYI :)

From: Nicola Widdis
Sent: Wednesday, 11 June 2008 08:50 a.m.
To: Belinda Krimp
Cc: Alistair Cross
Subject: Petone Pure Water - Daily abstraction readings for May 2008



WGN_DOCS-54215
PDF.DRF (4 KB)...

Wgn 104/10360

Amy Holden

From: Alistair Cross
Sent: Monday, 12 May 2008 03:13 p.m.
To: Amy Holden
Subject: FW: Petone Pure Water - Daily abstraction readings for April 2008
Attachments: WGN_DOCS-533787.PDF

From: Nicola Widdis
Sent: Monday, 12 May 2008 12:13 p.m.
To: Alistair Cross
Subject: Petone Pure Water - Daily abstraction readings for April 2008

Petone Pure Water Standard Form

Reference Number: PP-FR-016
Title: Abstraction Record
Prepared By: Andrew Torrance
Location: Petone Pure Water Plant
Date: 7 April, 2008

.....
To: Greater Wellington Resource Consents Management Fax 3856960

From: Petone Pure Water Co Ltd.

Daily Abstraction on a monthly basis.

Month April **Year** 2008

Equipment

GF Signet transmitter model 8550 integral mounted to GF Signet sensor 3-8510

Flow meter installed April 2005

Total Litres at start of month 1947820

Day	Daily litres	Total litres	Day	Daily litres	Total litres
1			17		
2			18		
3			19		
4			20		
5			21		
6			22		
7			23		
8			24		
9	<u>20548</u>	<u>1968368</u>	25		
10	<u>19231</u>	<u>1987599</u>	26		
11			27		
12			28	<u>18564</u>	<u>2006163</u>
13			29	<u>12004</u>	<u>2018167</u>
14			30		
15			31		
16					

Total seven day abstraction 1-7 NIL
 Total seven day abstraction 8-15 39779
 Total seven day abstraction 16-23 NIL
 Total seven day abstraction 24-31 30568
 Total time on bypass = NIL
 Flow rate on bypass 2litres/m
 Total Month 70347
 Sign off Manager A Torrance

Amy Holden

From: Alistair Cross
Sent: Monday, 7 April 2008 11:44 a.m.
To: Amy Holden
Subject: FW: Petone Pure Water - daily abstraction readings for March 2008

Attachments: WGN_DOCS-524768.PDF

From: Nicola Widdis
Sent: Monday, 7 April 2008 10:42 a.m.
To: Alistair Cross
Subject: Petone Pure Water - daily abstraction readings for March 2008



vGN_DOCS-#5247
68-v1-Petone_Pur...

To: Greater Wellington Resource Consents Management Fax 3856960

From: **Petone Pure Water Co Ltd.**

Daily Abstraction on a monthly basis.

Month March Year 2008

Equipment

GF Signet transmitter model 8550 integral mounted to GF Signet sensor 3-8510

Flow meter installed April 2005

Total Litres at start of month 1916974

Day	Daily litres	Total litres	Day	Daily litres	Total litres
1			17		
2			18		
3			19		
4	<u>16604</u>	<u>1933578</u>	20	<u>14242</u>	<u>1947820</u>
5			21		
6			22		
7			23		
8			24		
9			25		
10			26		
11			27		
12			28		
13			29		
14			30		
15			31		
16					

Total seven day abstraction 1-7 16604
 Total seven day abstraction 8-15 _____
 Total seven day abstraction 16-23 14242
 Total seven day abstraction 24-31 _____
 Total time on bypass = NIL
 Flow rate on bypass 2litres/m

Total Month 30,946

Sign off Manager *[Signature]*

WGN/04/0360/1-#

518059

Amy Holden

From: Alistair Cross
Sent: Thursday, 6 March 2008 11:58 a.m.
To: Amy Holden
Subject: FW: Petone Pure Water - Daily abstraction readings for February 2008
Attachments: WGN_DOCS-516589.PDF

From: Nicola Widdis
Sent: Monday, 3 March 2008 01:13 p.m.
To: Alistair Cross
Subject: Petone Pure Water - Daily abstraction readings for February 2008



WGN_DOCS-#5165
89-v1-Petone_Pur...

To: Greater Wellington Resource Consents Management Fax 3856960

From: **Petone Pure Water Co Ltd.**

Daily Abstraction on a monthly basis.

Month Feb Year 2008

Equipment

GF Signet transmitter model 8550 integral mounted to GF Signet sensor 3-8510

Flow meter installed April 2005

Total Litres at start of month 1879721

Day	Daily litres	Total litres	Day	Daily litres	Total litres
1			17		
2			18		
3			19	24967	1904688
4			20		
5			21		
6			22		
7			23		
8			24		
9			25		
10			26		
11			27		
12			28	12286	1916974
13			29		
14			30		
15			31		
16					

Total seven day abstraction 1-7 NIL
 Total seven day abstraction 8-15 NIL
 Total seven day abstraction 16-23 24967
 Total seven day abstraction 24-31 12286
 Total time on bypass = NIL
 Flow rate on bypass 2litres/m

Total Month 37253

Sign off Manager *J. J. J.*

wgn/104/0360

#510519

Amy Holden

From: Alistair Cross
Sent: Thursday, 7 February 2008 10:06 a.m.
To: Amy Holden
Subject: FW: Petone Pure Water - Daily abstraction readings for January 2008

Attachments: WGN_DOCS-510519.PDF

From: Nicola Widdis
Sent: Tuesday, 5 February 2008 04:21 p.m.
To: Alistair Cross
Subject: Petone Pure Water - Daily abstraction readings for January 2008



WGN_DOCS-#5105
19-v1-Petone_Pur...

To: Greater Wellington Resource Consents Management Fax 3856960

From: **Petone Pure Water Co Ltd.**

Daily Abstraction on a monthly basis.

Month Jan. Year 2007-2008

Equipment

GF Signet transmitter model 8550 integral mounted to GF Signet sensor 3-8510

Flow meter installed April 2005

Total Litres at start of month 1804690

Day	Daily litres	Total litres	Day	Daily litres	Total litres
1			17		
2			18		
3			19		
4			20		
5			21		
6			22	<u>29176</u>	<u>1879721</u>
7			23		
8			24		
9	<u>36837</u>	<u>1841527</u>	25		
10			26		
11			27		
12			28		
13			29		
14			30		
15	<u>9018</u>	<u>1850545</u>	31		
16					

Total seven day abstraction 1-7 NIL
 Total seven day abstraction 8-15 45855
 Total seven day abstraction 16-23 29176
 Total seven day abstraction 24-31 NIL
 Total time on bypass = NIL
 Flow rate on bypass 2litres/m

Total Month 75031

Sign off Manager *[Signature]*

wgn/04/0360

Amy Holden

From: Alistair Cross
Sent: Monday, 7 January 2008 03:53 p.m.
To: Amy Holden
Subject: FW: Petone Pure Water - Daily abstraction readings for December 2007

Attachments: WGN_DOCS-504121.PDF

From: Nicola Widdis
Sent: Monday, 7 January 2008 03:52 p.m.
To: Alistair Cross
Subject: Petone Pure Water - Daily abstraction readings for December 2007



WGN_DOCS-#5041
21-v1-Petone_Pur...

To: Greater Wellington Resource Consents Management Fax 3856960

From:

Petone Pure Water Co Ltd.

Daily Abstraction on a monthly basis.

Month *Dec.* Year 2007

Equipment

GF Signet transmitter model 8550 integral mounted to GF Signet sensor 3-8510

Flow meter installed April 2005

Total Litres at start of month 1763277.

Day	Daily litres	Total litres	Day	Daily litres	Total litres
1			17		
2			18		
3			19		
4			20	10049	1804690
5	10836	1774113	21		
6	14339	1788452	22		
7			23		
8			24		
9			25		
10	6189	1794641	26		
11			27		
12			28		
13			29		
14			30		
15			31		
16					

Total seven day abstraction 1-7 25175
 Total seven day abstraction 8-15 6189
 Total seven day abstraction 16-23 10049
 Total seven day abstraction 24-31 _____
 Total time on bypass = NIL
 Flow rate on bypass 2litres/m

Total Month 41413.

Sign off Manager



Amy Holden

From: Alistair Cross
Sent: Wednesday, 5 December 2007 09:34 a.m.
To: Amy Holden
Subject: FW: Petone Pure Water - Daily abstraction readings for November 2007

Attachments: WGN_DOCS-497991.PDF

From: Nicola Widdis
Sent: Wednesday, 5 December 2007 09:34 a.m.
To: Alistair Cross
Subject: Petone Pure Water - Daily abstraction readings for November 2007



WGN_DOCS-#4979
-v1-Petone_Pur...

To: Greater Wellington Resource Consents Management Fax 3856960

From:

Petone Pure Water Co Ltd.

Daily Abstraction on a monthly basis.

Month

Year

2007

Equipment

GF Signet transmitter model 8550 integral mounted to GF Signet sensor 3-8510

Flow meter installed April 2005

Total Litres at start of month 1704679

Day	Daily litres	Total litres	Day	Daily litres	Total litres
1			17		
2			18		
3			19		
4			20		
5			21	13458	1732976
6			22	16791	1749767
7			23		
8			24		
9			25		
10			26		
11			27	5242	1755009
12			28		
13	7015	1711694	29	8268	1763277
14	7824	1719518	30		
15			31		
16					

Total seven day abstraction 1-7

NIL

Total seven day abstraction 8-15

14839.

Total seven day abstraction 16-23

30249

Total seven day abstraction 24-31

13510

Total time on bypass

NIL

Flow rate on bypass 2litres/m

Total Month

58598

Sign off Manager



wgn 04/p360

Amy Holden

From: Alistair Cross
Sent: Tuesday, 6 November 2007 03:53 p.m.
To: Amy Holden
Subject: FW: Petone Pure Water - Daily abstraction readings for October 2007

Attachments: WGN_DOCS-489971.PDF

From: Alison McGray
Sent: Tuesday, 6 November 2007 09:07 a.m.
To: Alistair Cross
Subject: Petone Pure Water - Daily abstraction readings for October 2007



wGN_DOCS-#4899
71-v1-Petone_Pur...

To: Greater Wellington Resource Consents Management Fax 3856960

From: **Petone Pure Water Co Ltd.**

Daily Abstraction on a monthly basis.

Month October. Year 2007

Equipment

GF Signet transmitter model 8550 integral mounted to GF Signet sensor 3-8510

Flow meter installed April 2005

Total Litres at start of month 1649325.

Day	Daily litres	Total litres	Day	Daily litres	Total litres
1			17		
2			18		
3			19	15427	1674058
4			20		
5			21		
6			22		
7			23		
8			24	9261	1683339
9			25		
10	8906	1658231	26		
11			27		
12			28		
13			29	12354	1695693
14			30	8986	1704679
15			31		
16					

Total seven day abstraction 1-7

Total seven day abstraction 8-15

Total seven day abstraction 16-23

Total seven day abstraction 24-31

Total time on bypass

Flow rate on bypass 2litres/m

8906
15427
30621
NIL

Total Month

55354

Sign off Manager

Jamane

Amy Holden

From: Alistair Cross
Sent: Monday, 1 October 2007 10:37 a.m.
To: Amy Holden
Subject: FW: Petone Pure Water - Daily abstraction readings for Sept 07

Attachments: WGN_DOCS-466181.PDF

From: Nicola Widdis
Sent: Monday, 1 October 2007 10:26 a.m.
To: Alistair Cross
Subject: Petone Pure Water - Daily abstraction readings for Sept 07



WGN_DOCS-#4661
l-v1-Petone_Pur...

~~WGN 040319~~
WGN 040360

To: Greater Wellington Resource Consents Management Fax 3856960

From: **Petone Pure Water Co Ltd.**

Daily Abstraction on a monthly basis.

Month September Year 2007

Equipment

GF Signet transmitter model 8550 integral mounted to GF Signet sensor 3-8510

Flow meter installed April 2005

Total Litres at start of month 1558674

Day	Daily litres	Total litres	Day	Daily litres	Total litres
1			17		
2			18	8961	1567635
3			19	20921	1588556
4			20	23582	1612138
5			21		
6			22		
7			23		
8			24		
9			25	37187	1649325
10			26		
11			27		
12			28		
13			29		
14			30		
15			31		
16					

Total seven day abstraction 1-7 NIL
 Total seven day abstraction 8-15 NIL
 Total seven day abstraction 16-23 53464
 Total seven day abstraction 24-31 37187
 Total time on bypass = NIL
 Flow rate on bypass 2litres/m

Total Month 90651

Sign off Manager 

4459310

04/03/07

W6N040360

To: Greater Wellington Resource Consents Management Fax 3856960

From: **Petone Pure Water Co Ltd.**

Daily Abstraction on a monthly basis.

Month *August* Year *2007*

Equipment

GF Signet transmitter model 8550 integral mounted to GF Signet sensor 3-8510

Flow meter installed April 2005

Total Litres at start of month *1487742*

Day	Daily litres	Total litres	Day	Daily litres	Total litres
1			17		
2			18		
3			19		
4			20		
5			21		
6			22		
7			23		
8			24		
9			25		
10			26		
11			27	<i>9217</i>	<i>1558674</i>
12			28		
13	<i>26916</i>	<i>1514658</i>	29		
14	<i>15468</i>	<i>1530126</i>	30		
15	<i>19325</i>	<i>1549457</i>	31		
16					

Total seven day abstraction 1-7 *NIL*
 Total seven day abstraction 8-15 *61709*
 Total seven day abstraction 16-23 *9217 NIL*
 Total seven day abstraction 24-31 *N 9217*
 Total time on bypass = *NIL*
 Flow rate on bypass 2litres/m

Total Month *70926*

Sign off Manager *[Signature]*

Amy Holden

From: Alistair Cross
Sent: Tuesday, 25 September 2007 01:18 p.m.
To: Amy Holden
Subject: FW: Petone Pure Water - Daily abstraction readings for August 2007

Attachments: WGN_DOCS-459310.PDF

From: Nicola Widdis
Sent: Monday, 3 September 2007 11:24 a.m.
To: Alistair Cross
Subject: Petone Pure Water - Daily abstraction readings for August 2007



WGN_DOCS-#4593
10-v1-Daily_wate...



6 August 2007

Petone Pure Water Company Limited
PO Box 38276
Wellington Mail Centre
Lower Hutt 5045

For: Andrew Torrance

Compliance monitoring report 2006/2007 for WGN040319 [23706] and WGN040360 [23776]

Consent holder:	<i>Petone Pure Water Company Limited</i>
Description:	<i>To take and use water from the Waiwhetu Artesian Aquifer.</i>
Location:	<i>Gear Island, Jackson Street, Petone</i>
Consent type:	<i>Water permits</i>

Thank you for your assistance during my inspection of your site on Thursday 14 June 2007. Your compliance assessment report is attached.

Annual compliance rating

WGN040319 [23706] and WGN040360 [23776] are rated as **fully complying** for the 2006/2007 compliance year.

Action required by consent holder

Please continue to comply with the conditions of your consent WGN040360 [23776].

No further action is required for consent WGN040319 [23706] as this expired on 9 March 2007 and was replaced by WGN040360 [23776].

Further assessments

As your consent is for an on-going activity another inspection will be made before 30 June 2008. You will be contacted closer to the time to arrange a suitable time to visit.

If you have any questions about the monitoring of your consent or your compliance assessment report please contact Amy Holden on 04 802 0335.

Trudy Richards
Administrative Assistant, Environmental Regulation

Date: 06/08/07

Annual compliance ratings:

These are based on the financial year, i.e., from 1 July to 30 June. Your annual compliance rating will be reported in the *Greater Wellington annual compliance report* which, after being presented to Greater Wellington's Environment Committee, becomes available to the public.

<i>Fully complying</i>	100 % compliance with all consent conditions at all times.
<i>Mainly complying</i>	Compliance with all conditions relating to environmental effects during the year. However, there may be minor non-compliance with administrative-type conditions, e.g., late (but by no more than one month) submission of management reports. All administrative conditions are met at the end of the financial year.
<i>Partially complying</i>	Compliance with all conditions relating to environmental effects during the year. However, there may be non-compliance with administrative-type conditions, e.g., late submission of management reports. The consent holder needs to be prompted by Wellington Regional Council before such administrative conditions are met at the end of the financial year.
<i>Non-complying</i>	Non-compliance with condition(s) relating to environmental effects during the financial year (this includes any confirmed complaints) and/or not all administrative-type conditions met at the end of the financial year.

Compliance assessment report 2006/2007

Consent number: WGN040319

Consent ID: [23706]

EXPIRED: 9 March 2007

Condition	Requirements	Requirements met			Comments	Date Assessed
		Yes ✓	No ✗	NA		
1	The location, design, implementation and operation of the take shall be in accordance with the consent application and associated plans and documents lodged with the Wellington Regional Council on 30 April 2004, and the transfer of permit applications lodged with the Wellington Regional Council on 20 May 2004 and 24 May 2004.	✓			The water take was operated in accordance with the consent application.	14 Jun 2007
2	The rate of abstraction shall not exceed 350 cubic metres over any seven day period.	✓			The rate of take was not exceeded during the 2006/2007 compliance year.	14 Jun 2007
3	The permit holder shall meter all abstractions and supply records of total daily abstraction to the Manager, Consents Management, Wellington Regional Council, on a monthly basis. The installed meter shall have an accuracy of +/- 5%.	✓			Records were received on a monthly basis between July 2006 and March 2007.	14 Jun 2007
4	Restrictions/rostering.			NA	Not requested this compliance year.	
5	Review condition.			NA	Not an inspection condition.	

Consent number: **WGN040360**

Consent ID: **[23776]**

Condition	Requirements	Requirements met			Comments	Date Assessed
		Yes ✓	No ✗	NA		
1	The location, design, implementation and operation of the take shall be in accordance with the consent application and associated plans and documents lodged with the Wellington Regional Council on 22 June 2004.	✓			The water take is being operated in accordance with the consent application.	14 Jun 2007
2	The rate of abstraction shall not exceed 350 cubic metres over any seven day period.	✓			The rate of take was not exceeded during the 2006/2007 compliance year.	14 Jun 2007
3	The permit holder shall meter all abstractions and supply records of total daily abstraction to the Manager, Consents Management, Wellington Regional Council, on a monthly basis. The installed meter shall have an accuracy of +/- 5%.	✓			Records were received on a monthly basis between March 2007 and June 2007.	14 Jun 2007
4	Restrictions/rostering.			NA	Not requested this compliance year.	
5	Review condition.			NA	Not an inspection condition.	

Trudy Richards
Administrative Assistant, Environmental Regulation



6 August 2007

Petone Pure Water Company Limited
PO Box 208
Wellington 6140

For: Barry Wilson

Compliance monitoring report 2006/2007 for WGN040319 [23706] and WGN040360 [23776]

<i>Consent holder:</i>	<i>Petone Pure Water Company Limited</i>
<i>Description:</i>	<i>To take and use water from the Waiwhetu Artesian Aquifer.</i>
<i>Location:</i>	<i>Gear Island, Jackson Street, Petone</i>
<i>Consent type:</i>	<i>Water permits</i>

Plant Manager Andrew Torrance assisted me during my inspection of your site on Thursday 14 June 2007. Your compliance assessment report is attached.

Annual compliance rating

WGN040319 [23706] and WGN040360 [23776] are rated as **fully complying** for the 2006/2007 compliance year.

Action required by consent holder

Please continue to comply with the conditions of your consent WGN040360 [23776].

No further action is required for consent WGN040319 [23706] as this expired on 9 March 2007 and was replaced by WGN040360 [23776].

Further assessments

As your consent is for an on-going activity another inspection will be made before 30 June 2008. You will be contacted closer to the time to arrange a suitable time to visit.

If you have any questions about the monitoring of your consent or your compliance assessment report please contact Amy Holden on 04 802 0335.

Trudy Richards
Administrative Assistant, Environmental Regulation

Date: 06/08/07

Annual compliance ratings:

These are based on the financial year, i.e., from 1 July to 30 June. Your annual compliance rating will be reported in the *Greater Wellington annual compliance report* which, after being presented to Greater Wellington's Environment Committee, becomes available to the public.

<i>Fully complying</i>	100 % compliance with all consent conditions at all times.
<i>Mainly complying</i>	Compliance with all conditions relating to environmental effects during the year. However, there may be minor non-compliance with administrative-type conditions, e.g., late (but by no more than one month) submission of management reports. All administrative conditions are met at the end of the financial year.
<i>Partially complying</i>	Compliance with all conditions relating to environmental effects during the year. However, there may be non-compliance with administrative-type conditions, e.g., late submission of management reports. The consent holder needs to be prompted by Wellington Regional Council before such administrative conditions are met at the end of the financial year.
<i>Non-complying</i>	Non-compliance with condition(s) relating to environmental effects during the financial year (this includes any confirmed complaints) and/or not all administrative-type conditions met at the end of the financial year.

Compliance assessment report 2006/2007

Consent number: WGN040319

Consent ID: [23706]


EXPIRED: 9 March 2007

Condition	Requirements	Requirements met			Comments	Date Assessed
		Yes ✓	No ✗	NA		
1	The location, design, implementation and operation of the take shall be in accordance with the consent application and associated plans and documents lodged with the Wellington Regional Council on 30 April 2004, and the transfer of permit applications lodged with the Wellington Regional Council on 20 May 2004 and 24 May 2004.	✓			The water take was operated in accordance with the consent application.	14 Jun 2007
2	The rate of abstraction shall not exceed 350 cubic metres over any seven day period.	✓			The rate of take was not exceeded during the 2006/2007 compliance year.	14 Jun 2007
3	The permit holder shall meter all abstractions and supply records of total daily abstraction to the Manager, Consents Management, Wellington Regional Council, on a monthly basis. The installed meter shall have an accuracy of +/- 5%.	✓			Records were received on a monthly basis between July 2006 and March 2007.	14 Jun 2007
4	Restrictions/rostering.			NA	Not requested this compliance year.	
5	Review condition.			NA	Not an inspection condition.	

Consent number: WGN040360

Consent ID: [23776]

Condition	Requirements	Requirements met			Comments	Date Assessed
		Yes ✓	No ✗	NA		
1	The location, design, implementation and operation of the take shall be in accordance with the consent application and associated plans and documents lodged with the Wellington Regional Council on 22 June 2004.	✓			The water take is being operated in accordance with the consent application.	14 Jun 2007
2	The rate of abstraction shall not exceed 350 cubic metres over any seven day period.	✓			The rate of take was not exceeded during the 2006/2007 compliance year.	14 Jun 2007
3	The permit holder shall meter all abstractions and supply records of total daily abstraction to the Manager, Consents Management, Wellington Regional Council, on a monthly basis. The installed meter shall have an accuracy of +/- 5%.	✓			Records were received on a monthly basis between March 2007 and June 2007.	14 Jun 2007
4	Restrictions/rostering.			NA	Not requested this compliance year.	
5	Review condition.			NA	Not an inspection condition.	



Trudy Richards
Administrative Assistant, Environmental Regulation

WGN 04 0360 Savec under 040319
451352

To: Greater Wellington Resource Consents Management Fax 3856960

From: **Petone Pure Water Co Ltd.**

Daily Abstraction on a monthly basis.

Month July Year 2007

Equipment
GF Signet transmitter model 8550 integral mounted to GF Signet sensor 3-8510

Flow meter installed April 2005

Total Litres at start of month 145665.2

Day	Daily litres	Total litres	Day	Daily litres	Total litres
1			17		
2			18		
3			19		
4			20	5455	1464107
5			21		
6			22		
7			23	8963	1473070
8			24	14672	1487742
9			25		
10			26		
11			27		
12			28		
13			29		
14			30		
15			31		
16					

Total seven day abstraction 1-7 _____
 Total seven day abstraction 8-15 _____
 Total seven day abstraction 16-23 14618
 Total seven day abstraction 24-31 14672
 Total time on bypass = NIL
 Flow rate on bypass 2litres/m

Total Month 29090

Sign off Manager *[Signature]*

To: Greater Wellington Resource Consents Management Fax 3856960

From: **Petone Pure Water Co Ltd.**

Daily Abstraction on a monthly basis.

Month July Year 2007

Equipment

GF Signet transmitter model 8550 integral mounted to GF Signet sensor 3-8510

Flow meter installed April 2005

Total Litres at start of month 1458652

Day	Daily litres	Total litres	Day	Daily litres	Total litres
1			17		
2			18		
3			19		
4			20	5455	1464107
5			21		
6			22		
7			23	8963	1473070
8			24	14672	1487742
9			25		
10			26		
11			27		
12			28		
13			29		
14			30		
15			31		
16					

Total seven day abstraction 1-7 _____
 Total seven day abstraction 8-15 _____
 Total seven day abstraction 16-23 14418
 Total seven day abstraction 24-31 14672
 Total time on bypass = NIL
 Flow rate on bypass 2litres/m _____

Total Month 29090

Sign off Manager *[Signature]*

To: Greater Wellington Resource Consents Management Fax 3856960

From: **Petone Pure Water Co Ltd.**

Daily Abstraction on a monthly basis.

Month June Year 2007

Equipment

GF Signet transmitter model 8550 integral mounted to GF Signet sensor 3-8510

Flow meter installed April 2005

Total Litres at start of month 1448843

Day	Daily litres	Total litres	Day	Daily litres	Total litres
1			17		
2			18		
3			19		
4			20		
5			21		
6			22	<u>9809</u>	<u>1458652</u>
7			23		
8			24		
9			25		
10			26		
11			27		
12			28		
13			29		
14			30		
15			31		
16					

Total seven day abstraction 1-7 _____
 Total seven day abstraction 8-15 _____
 Total seven day abstraction 16-23 9809
 Total seven day abstraction 24-31 _____
 Total time on bypass = NIL
 Flow rate on bypass 2litres/m _____

Total Month 9809 9.809m³

Sign off Manager *[Signature]*

*Sorry about delay have being on annual leave.
Andrew.*

04/0360

WGN040360

To: Greater Wellington Resource Consents Management Fax 3856960

From: Petone Pure Water Co Ltd.

Daily Abstraction on a monthly basis.

Month May Year 2007

Equipment
GF Signet transmitter model 8550 integral mounted to GF Signet sensor 3-8510

Flow meter installed April 2005

Total Litres at start of month 1415660

Day	Daily litres	Total litres	Day	Daily litres	Total litres
1			17		
2			18		
3			19		
4			20		
5			21		
6			22	15579	1431239
7			23		
8			24		
9			25		
10			26		
11			27		
12			28		
13			29		
14			30		
15			31	17604	1448843
16					

Total seven day abstraction 1-7 _____
 Total seven day abstraction 8-15 _____
 Total seven day abstraction 16-23 15579
 Total seven day abstraction 24-31 17604
 Total time on bypass = NIL
 Flow rate on bypass 2litres/m

Total Month 33183 33.183m³

Sign off Manager *[Signature]*

WGN040360

WGN 040360

To: Greater Wellington Resource Consents Management Fax 3856960

From: **Petone Pure Water Co Ltd.**

Daily Abstraction on a monthly basis.

Month April Year 2007

Equipment

GF Signet transmitter model 8550 integral mounted to GF Signet sensor 3-8510

Flow meter installed April 2005

Total Litres at start of month 1362162

Day	Daily litres	Total litres	Day	Daily litres	Total litres
1			17		
2			18		
3	6498	1368660	19		
4			20		
5	16320	1384980	21		
6			22		
7			23		
8			24	14360	1415660
9			25		
10			26		
11			27		
12			28		
13			29		
14			30		
15			31		
16	21365	1401300			

Total seven day abstraction 1-7 _____

Total seven day abstraction 8-15 _____

Total seven day abstraction 16-23 _____

Total seven day abstraction 24-31 _____

Total time on bypass = _____

Flow rate on bypass 2litres/m

Total Month 53498 53.498m³

Sign off Manager _____

WGN 04 0360

To: Greater Wellington Resource Consents Management Fax 3856960

From: **Petone Pure Water Co Ltd.**

Daily Abstraction on a monthly basis.

Month *March* Year 2007

Equipment

GF Signet transmitter model 8550 integral mounted to GF Signet sensor 3-8510

Flow meter installed April 2005

Total Litres at start of month 1347187

Day	Daily litres	Total litres	Day	Daily litres	Total litres
1			17		
2			18		
3			19		
4			20		
5			21		
6			22		
7			23		
8			24		
9			25		
10			26		
11	<i>10634</i>	<i>1357821</i>	27		
12			28		
13			29		
14	<i>4341</i>	<i>1362162</i>	30		
15			31		
16					

Total seven day abstraction 1-7 0
 Total seven day abstraction 8-15 14975
 Total seven day abstraction 16-23 0
 Total seven day abstraction 24-31 0
 Total time on bypass = NIL
 Flow rate on bypass 2litres/m

Total Month 14975 *14.975m³*

Sign off Manager *A. Errami*

WGN 040360

WGN 04 0360

To: Greater Wellington Resource Consents Management Fax 3856960

From: **Petone Pure Water Co Ltd.**

Daily Abstraction on a monthly basis.

Month Feb Year 2007

Equipment

GF Signet transmitter model 8550 integral mounted to GF Signet sensor 3-8510

Flow meter installed April 2005

Total Litres at start of month 1288197

Day	Daily litres	Total litres	Day	Daily litres	Total litres
1			17		
2			18		
3			19		
4			20		
5			21	16328	1325392
6			22		
7			23		
8	20867	1309064	24		
9			25		
10			26	21795	1347687
11			27		
12			28		
13			29		
14			30		
15			31		
16					

Total seven day abstraction 1-7 0
 Total seven day abstraction 8-15 20867
 Total seven day abstraction 16-23 16328
 Total seven day abstraction 24-31 21795
 Total time on bypass = NIL
 Flow rate on bypass 2litres/m

Total Month 58990 58.990m³

Sign off Manager *[Signature]*

WGN 04 0360

To: Greater Wellington Resource Consents Management Fax 3856960

From:

Petone Pure Water Co Ltd.

Daily Abstraction on a monthly basis.

Month *January* Year 2007

Equipment

GF Signet transmitter model 8550 integral mounted to GF Signet sensor 3-8510

Flow meter installed April 2005

Total Litres at start of month 1233934

Day	Daily litres	Total litres	Day	Daily litres	Total litres
1			17		
2			18		
3			19		
4			20		
5			21		
6			22		
7			23		
8	<i>8682</i>	<i>1242816</i>	24		
9			25		
10			26		
11	<i>23498</i>	<i>1266314</i>	27		
12			28		
13			29		
14			30	<i>21883</i>	<i>1288197</i>
15			31		
16					

Total seven day abstraction 1-7 0
 Total seven day abstraction 8-15 32580
 Total seven day abstraction 16-23 21883
 Total seven day abstraction 24-31 21883
 Total time on bypass = _____
 Flow rate on bypass 2litres/m

Total Month 54263 *54.263 m³*

Sign off Manager *Marvance*

WGN040360

WGN 04 0360

To: Greater Wellington Resource Consents Management Fax 3856960

From: **Petone Pure Water Co Ltd.**

Daily Abstraction on a monthly basis.

Month December Year 2006

Equipment

GF Signet transmitter model 8550 integral mounted to GF Signet sensor 3-8510


Flow meter installed April 2005

Total Litres at start of month 1232543

Day	Daily litres	Total litres	Day	Daily litres	Total litres
1			17		
2			18		
3			19		
4			20	1391	1233934
5			21		
6			22		
7			23		
8			24		
9			25		
10			26		
11			27		
12			28		
13			29		
14			30		
15			31		
16					

Total seven day abstraction 1-7 _____
 Total seven day abstraction 8-15 _____
 Total seven day abstraction 16-23 1391
 Total seven day abstraction 24-31 _____
 Total time on bypass = NIL
 Flow rate on bypass 2litres/m

Total Month 1391 1.391m³

Sign off Manager 

WAN 240360 [23776]

To: Greater Wellington Resource Consents Management Fax 3856960

From:

Petone Pure Water Co Ltd.

Daily Abstraction on a monthly basis.

Month *November* Year 2006

Equipment

GF Signet transmitter model 8550 integral mounted to GF Signet sensor 3-8510

Flow meter installed April 2005

Total Litres at start of month *1134124*

Day	Daily litres	Total litres	Day	Daily litres	Total litres
1	<i>17599</i>	<i>1151723</i>	17		
2			18		
3			19		
4			20		
5			21	<i>8432</i>	<i>1189168</i>
6			22		
7	<i>12589</i>	<i>1164312</i>	23		
8			24		
9	<i>9582</i>	<i>1173894</i>	25		
10			26		
11			27		
12			28		
13			29	<i>15256</i>	<i>1204424</i>
14			30	<i>28119</i>	<i>1232543</i>
15			31		
16	<i>6842</i>	<i>1180736</i>			

Total seven day abstraction 1-7 *30188*
 Total seven day abstraction 8-15 *9582*
 Total seven day abstraction 16-23 *15274*
 Total seven day abstraction 24-31 *43375*
 Total time on bypass = *NIL*
 Flow rate on bypass 2litres/m

Total Month *98419* *98.419 m³*

Sign off Manager

[Signature]

WGN040360



P O Box 11646
142 Wakefield Street
Wellington
New Zealand

T 04 384 5708 Wellington
F 04 385 6960 Wellington
T 06 378 2484 Masterton
F 06 378 2146 Masterton

Greater Wellington is the promotional name
of the Wellington Regional Council

Tax Credit Note

GST No: 39-344-939

Petone Pure Water Company Ltd
PO Box 208
WELLINGTON

Customer No: 16974

Credit Note Date: 04 November 2005

Credit Note No: 1600006005

Page: 1 of 1

Customer Reference: 18-48711

Particulars	Total
Consent not to exercised until the year 2007	233.40

This amount has been credited to your account.

Please advise of any changes of details overleaf.

Subtotal	233.40
GST	29.18
Total	262.58

Credit Note
DO NOT PAY

Customer Name:	Petone Pure Water Company Ltd
Customer No:	16974
Credit Note Date:	04 November 2005
Credit Note No:	1600006005
This Credit Note:	\$262.58

Tax Credit Note

GST No: 39-344-939

Customer No: 16974

Credit Note Date: 13 September 2004

Credit Note No: 1600004512

Page: 1 of 1

Petone Pure Water Company Ltd
PO Box 208
WELLINGTON

Customer Reference: 1800038344

WGN040360

iculars	Total
Invoice raised in duplication	245.00
COPY	

This amount has been credited to your account.

Please advise of any changes of details overleaf.

Subtotal	245.00
GST	30.63
Total	275.63

Credit Note

DO NOT PAY

Customer Name: Petone Pure Water Company Ltd

Customer No: 16974

Credit Note Date: 13 September 2004

Credit Note No: 1600004512

This Credit Note: \$275.63

COPY

12 July 2004
File: WGN040360 [23776]
WGN_DOCS-#215681-v1

Non-notified resource consent application officer's report

Application granted with conditions

Date Granted: 12 July 2004

Date Effective: 9 March 2007

Applicant: Petone Pure Water Company Limited
P O Box 208
Wellington

Consent Granted: **WGN040360 [23776]: Non-complying Activity**
To take and use water from the Waiwhetu Artesian
Aquifer.

Location: Gear Island, Jackson Street, Petone

Map Reference: At or about map reference NZMS 260:R27;691.955

Legal Description: Lot 1 DP 52099

Duration of Consent: WGN040360 [23776]: 15 years

Conditions Relate to: Rate of abstraction, recording abstraction volumes and
forwarding records to Greater Wellington, protecting the
aquifer from saline intrusion.

Report prepared by:



MIRANDA ROBINSON
Resource Advisor, Consents Management

Recommendation approved:


for

LUCI RYAN
Manager, Consents Management

49

Reasons for decision: resource consent WGN040360 [23776]

1. Background

Petone Pure Water Company Limited (the applicant) was granted water permit WGN040319 [23706] on 9 June 2004. This permit authorises the taking of up to 350m³ of water from the Waiwhetu Artesian Aquifer over any seven day period from a bore located at Gear Island, Petone. This volume of water was transferred from water permit WGN980053 held by the Strategy and Asset Department, Greater Wellington.

As water permit WGN040319 arose from a transfer, it has the same expiry date as the original consent (WGN980053), which is 9 March 2007.

2. Proposal

The applicant is establishing a water bottling plant in Lower Hutt. The plant will be a commercial plant, producing bottled water under the brand name "Petone Pure" and other names for different markets. The primary target market is Hutt City and the Wellington region. The applicant also hopes to establish an export market. The applicant has an agreement with the Strategy and Asset Department of Greater Wellington Regional Council (Greater Wellington) that in the event of a natural disaster the entire production of the plant would be diverted to the needs of residents in the greater Wellington area.

The bottling plant is located on land owned by Unilever New Zealand Limited, Jackson Street, Petone.

In order to gain some surety of supply, essential for the investment in the bottling plant, the applicant has applied early to 'renew' water permit WGN040319, for a longer term.

3. Consultation

In accordance with the agreement between Greater Wellington and local iwi in relation to non-notified consents, the application has been sent to Wellington Tenth Trust and Te Runanganui o Taranaki Whanui ki te Upoko o te Ika a Maui.

Teri Puketapu responded on behalf of Te Runanganui o Taranaki Whanui ki te Upoko o te Ika a Maui, and advised he had initial concerns with the application. The iwi raised concerns over the proposed use of the water, i.e., the sale of the water, from a moral and ethical perspective. A meeting was held between members of the iwi and Greater Wellington staff to discuss these matters. Mr Puketapu has since responded that the iwi have no comment to make on the application.

Wellington Tenth Trust requested a full copy of the application. Liz Mellish responded on behalf of Wellington Tenth Trust. Ms Mellish considered the

application did not address the cultural landscape or Treaty of Waitangi claim settlement matters as required by section 8 of the Resource Management Act 1991. Additionally Ms Mellish was unhappy that neither the applicant nor the Strategy and Asset Department of Greater Wellington had consulted with the Trust. Wellington Tenth Trust does not support the application, and do not agree to the 20-year term sought by the applicant.

The applicant has also consulted with Murray Kennedy, Manager of the Strategy and Asset Department, Greater Wellington, and obtained his written approval for the proposal. As the largest user of water from the Waiwhetu Artesian Aquifer, I consider the Strategy and Asset Department, Greater Wellington to be an interested party to this application.

4. Environmental effects

The Hutt aquifer system is an important water resource, supplying approximately 40 percent of the regional demand for public water supply. Water from the aquifer is also used extensively by local industry.

An assessment of potential effects of the abstraction was undertaken by Andrew Jones, Greater Wellington Regional Council's Groundwater Scientist. Mr Jones considers that the volume of the proposed take is sufficiently small to have no appreciable effect on the water pressure in the aquifer, in particular at the McEwan Park monitoring site. Accordingly the proposed take will not increase the potential for saline intrusion into the ground water system, nor will it exacerbate low pressures should they occur naturally or be induced by pumping by other users.

All potential effects of the take stem from the location and rate of abstraction. The potential effects of the abstraction include; saline (saltwater) intrusion, ground subsidence, effects on surface water bodies and effects on other users.

4.1 Saline intrusion

Where an aquifer is in hydraulic connection with the ocean there is the risk of saline intrusion if the abstraction rates are too high. The prevention of saline intrusion is one of the main objectives of the management of the Waiwhetu Aquifer. Given the low rate of take applied for, it is unlikely saline intrusion will be significantly influenced. The water level trigger recommended in condition 4 will ensure the potential for saline intrusion as a result of this take is minimal.

4.2 Ground subsidence

The Waiwhetu Aquifer is an artesian system, therefore the abstraction of water causes a reduction of water pressure in the aquifer and not the water level. Therefore, subsidence should not occur. The water level trigger recommended in condition 4 will further reduce the potential for ground subsidence.



4.3 Effects on surface water bodies

The Lower Hutt Groundwater Zone (which includes the Waiwhetu Aquifer) is largely recharged by water from the Hutt River, particularly during times of high river flow. Consequently, river flows have the potential to be affected by groundwater abstraction. However, given the low rate of take, there will be no measurable effect on the Hutt River. Again, the water level trigger recommended will reduce the potential effects on flow in the Hutt River.

4.4 Effects on other users

Groundwater abstraction from an artesian aquifer system has the effect of drawing down the artesian water pressure in the well and surrounding aquifer. Given the low rate of take, it is very unlikely the drawdown induced would affect any other users of the aquifer. The closest other user of the aquifer is the Strategy and Asset Department, Greater Wellington, who take groundwater for public water supply. The Strategy and Asset Department has no concerns with the application.

4.5 Sustainability of abstraction

Currently this aquifer is over-allocated. The Regional Freshwater Plan for the Wellington Region (RFP) gives a maximum safe yield from the aquifer of 90,000 m³ per day. At present a total of 94,735 m³ per day has already been allocated. As such, any further applications for water permits from the Waiwhetu Artesian Aquifer are discouraged, and are classed as *non-complying* activities. Given that the applicant currently holds a water permit, and is not applying to increase the volume of water taken, I consider that the 'renewal' of the permit is consistent with the sustainable management of the Waiwhetu Aquifer.

5. Statutory framework

5.1 Resource Management Act 1991

Part II (Section 5) of the Resource Management Act 1991 (the Act) defines its purpose as the promotion of sustainable management of natural and physical resources. Sections 6, 7 and 8 of Part II of the Act define the matters a consent authority shall consider when achieving this purpose. I consider that the proposal relating to this consent application is consistent with Part II of the Act.

Under section 14 of the Act, restrictions are placed on taking and using water, including groundwater. The taking, using, damming and diversion of any water, is not permitted unless expressly allowed by a rule in a regional plan or resource consent.

The taking and use of up to 350m³ of groundwater over any seven day period is not expressly allowed by a rule in the RFP, therefore, resource consent is required. The existing resource consent only authorises the taking of water

until 9 March 2007. Taking water beyond this time requires a new consent, which is the subject of this application.

5.2 Regional plans

Rule 19 of the RFP specifies that the taking of fresh water from the Lower Hutt Groundwater Zone (Taita Alluvium/Waiwhetu aquifers) that would cause the maximum rate of takes authorised by resource consents to exceed 32.85 million cubic metres per year is a *non-complying activity*. Currently the total combined takes from the Lower Hutt Groundwater Zone authorised by resource consents, including the volume of this application, is approximately 34.58 million cubic metres per year. As such the take, which is the subject of this application, is classed as a *non-complying activity*.

I have reviewed the objectives and policies of the RFP, and I consider that the application is consistent with the relevant policies contained in Sections 4 and 6 of the RFP.

In particular, Policy 4.2.29 recognises the needs of existing lawful users of freshwater. This policy provides for priority to be given to existing users over new users at locations where the demand for the use of the water is greater than the resource can sustain. The policy recognises that resource users are entitled to have some security of operation which recognises their existing investment so long as they are exercising their take in accordance with any rule in the RFP or resource consent.

Policy 6.2.3 specifies the aquifer allocation limits for groundwater zones in the Region. This application proposes to take water from the Lower Hutt Groundwater Zone, at a depth of approximately 30 metres. As discussed above, the maximum safe yield from this aquifer is 90,000m³/day, and the current daily allocation from the aquifer is 94,735m³. This policy considers that a take causing more to be taken from the aquifer than is provided by the daily safe yields may be allowed by a water permit if the applicant can demonstrate that the sustainable yield of the aquifer is not compromised in any way, other users of the resource are not unduly affected, and there are no significant effects on surface water.

Policy 6.2.8 seeks to ensure that water permits to take groundwater consider effects on nearby bores and avoid significant adverse effects on surface water bodies.

5.3 Regional Policy Statement

The Regional Policy Statement for the Wellington Region (RPS) contains several objectives and policies aimed at maintaining the quality of the freshwater environment. These objectives and policies are intended to provide for the current and reasonably foreseeable needs of current and future generations. The relevant chapters of the RPS are Chapter 5 (Freshwater) and Chapter 9 (Ecosystems). The proposed abstraction of groundwater for sale commercially and for supply during emergency situations, is consistent with these objectives and policies.



6. Reasons for waiver of notification

I consider that notification under Section 93 of the Act is not required, as the effects of the proposed abstraction on the environment will be minor.

Section 94(2) of the Act provides that a consent authority is not required to serve notice of the application under subsection (1) if all persons who, in the opinion of the consent authority, may be adversely affected by the take have given their written approval.

I do not consider there to be any affected parties.

Section 104D of the Act outlines particular restrictions for non-complying activities, whereby despite any decision made for the purpose of Section 93 of the Act in relation to minor effects, a consent authority may grant a resource consent for a non-complying activity only if it is satisfied that either:

- (a) *the adverse effects of the activity on the environment (other than any effect to which section 104(3)(b) applies) will be minor; or*
- (b) *the application is for an activity that will not be contrary to the objectives and policies of the relevant plan...*

As stated above, I consider that the adverse effects on the environment from the proposed works will be minor and the activity is not contrary to the objectives and policies in the RFP.

7. Term of consent

The applicant has requested a term of 20 years.

Other water permits to take water from the Lower Hutt Aquifer have consent terms of 10 years, with the exception of those permits for public and emergency water supply purposes. A consent term of 10 years has been considered appropriate for water permits to take from the aquifer to enable Greater Wellington to retain adequate control over the aquifer, which is currently over allocated.

Although not primarily for emergency water supply purposes, it is considered that the emergency water supply aspect of this permit should be given due consideration when determining the term of permit. In this instance it is considered that a longer term of 15 years is warranted.

This permit will take effect from 9 March 2007 (the expiry date of the current permit), thereby effectively giving the applicant 18 years security of supply. Although this recommended term is less than the 20 years applied for, I consider it is adequate to provide economic certainty for the applicant whilst at the same time allowing Greater Wellington appropriate control over water allocation from the aquifer.

8. Recommendation

That under sections 104D and 108 of the Resource Management Act 1991, Petone Pure Water Company Limited be granted the following non-notified consent.

***Water permit WGN040360 [23776]** to take and use water from the Waiwhetu Artesian Aquifer at or about map reference NZMS 260:R27;691.955, for a term of fifteen years effective from 9 March 2007, subject to the following conditions:*

- (1) The location, design, implementation and operation of the take shall be in accordance with the consent application and associated plans and documents lodged with the Wellington Regional Council on 22 June 2004.*
- (2) The rate of abstraction shall not exceed 350 cubic metres over any seven day period.*
- (3) The permit holder shall meter all abstractions and supply records of total daily abstraction to the Manager, Consents Management, Wellington Regional Council, on a monthly basis. The installed meter shall have an accuracy of +/- 5%.*
- (4) If the pressure in the Waiwhetu Artesian Aquifer drops to an average, over a 24 hour period, of +2.3 metres above datum, as measured by the McEwan Park (site number 1428009) water level monitoring station, or any other official Wellington Regional Council water level monitoring station in the Petone and Seaview area, the permit holder shall comply with all abstraction restrictions and/or rostering as directed by the Manager, Consents Management, Wellington Regional Council.*
- (5) The Wellington Regional Council may review any or all of the conditions of this permit by giving notice of its intention to do so pursuant to section 128 of the Resource Management Act 1991, at any time within six months of the first, second, fifth and tenth anniversaries of the date of commencement of this consent to deal with any adverse effects on the environment that may arise from the exercise of this consent, and which are appropriate to deal with at a later stage.*

9. Reason for conditions

Adherence to the above conditions for resource consent WGN040360 [23776] will ensure that the abstraction of water from the Waiwhetu Artesian Aquifer has no more than a minor effect on the aquifer and surrounding environs, and other users of the aquifer.



Application Lodged: 21/06/04 **Application Officially Received:** 22/06/04

Decision to be Notified by: 20/07/04 **Decision Notified:** 12/07/04

Time Taken to Process Application: 14 working days

COPY

File No: WGN040360 [23776]
12 July 2004

Petone Pure Water Company Limited
P O Box 208
Wellington

Attention: Barry Wilson

P O Box 11 646
142 Wakefield Street
Wellington
New Zealand
T 04 384 5708
F 04 385 6960
W www.gw.govt.nz

Greater Wellington is the promotional
name of the Wellington Regional Council

Dear Mr Wilson

WGN040360 non-notified resource consent application: notice of decision

<i>Applicant:</i>	<i>Petone Pure Water Company Limited</i>
<i>Proposals:</i>	<i>To take and use water from the Waiwhetu Artesian Aquifer</i>
<i>Location:</i>	<i>Gear Island, Jackson Street, Petone</i>
<i>Resource consents required:</i>	<i>Water permit</i>

I am pleased to inform you that on 12 July 2004 your application was granted. I have enclosed a copy of the report outlining the reasons for this decision and the consent certificate¹. If you have any questions or concerns about any aspect of your consent, I would be happy to discuss them with you.

Your water permit is effective from 9 March 2007, at which time it will replace your current permit WGN040319 [23706].

Charges to expect

1. Costs incurred in processing your application

An invoice is enclosed for the costs incurred in processing your application. This charge is reduced by the application fee you have already paid. The breakdown of the costs is as follows:

¹ You have the right to object to our decision under section 357(2) of the Resource Management Act 1991. Your objection must be in writing and be made within 15 working days of receiving this letter.

WJ

Consent processing time: 4.5 hours @ \$70/hour	\$	315.00
Less application fee	\$	245.00
		<hr/>
Subtotal	\$	70.00
GST	\$	8.75
		<hr/>
Additional consent processing charge	\$	78.75 (Invoiced enclosed)
		<hr/>

2. Ongoing annual consent monitoring and service charges

Because your consent WGN040360 [23776] has on-going environmental effects Greater Wellington will monitor your take for compliance with your consent conditions until your consent expires. An explanation of the components of your annual charge can be found at the end of this letter.

Consent ID		[23776]
Customer service fee	\$	35.00
Compliance monitoring charge	\$	175.00
State of the environment monitoring charge	\$	23.35
		<hr/>
Subtotal	\$	233.35
GST	\$	29.17
		<hr/>
Total annual monitoring charge due	\$	262.52 (Invoiced in October 2007)
		<hr/>

Consent duration

Your water permit is effective from 9 March 2007 and expires on 9 March 2022. We will send you a reminder letter prior to the expiry date of the water permit so that you may apply for a new one.

Please note that, under section 125 of the Resource Management Act 1991 (as amended in 2003), your consent will lapse in five years unless you begin to use it before then.

Consent transfers

If you sell or transfer management of the business, it is important that you complete a Transfer of Permit form so that future owners can take responsibility for the consent. If you do not complete a transfer, you will continue to be liable for the annual consent monitoring and service charges associated with the consent.

Please feel free to contact your account manager, Al Cross, or myself on 381 7771, if you have any questions or concerns.

Yours sincerely



Miranda Robinson
Resource Advisor, Consents Management

Encl:

Components of your annual charge

Your charge is made up of several components. These components do not necessarily apply to all consents, so you may have only one or two of the following on your invoice:

- ***Customer Service Charge***: This charge applies to all consents. It covers administrative services such as providing information and advice about your consent, maintaining your consent as a public record and recording changes in consent status (for example, if you surrender your consent or transfer it to another person).
- ***Compliance Monitoring Charge***: The purpose of compliance monitoring is to confirm that you are meeting the conditions of your consent(s). To do this, we will undertake a site visit to assess your operations compliance with the conditions and report our results back to you. Your compliance monitoring is tailored to your individual circumstances. You pay only for the cost of monitoring your consent.
- ***State of the Environment Monitoring Charge (SOE Charge)***: Greater Wellington undertakes a wide range of monitoring to assess the state of the environment. For those catchments identified as being under stress, a small proportion of the monitoring costs is passed on to the consent holders (who hold consents in that stressed catchment). The amount you pay for state of the environment monitoring is proportional to the amount of water you take or contaminants you discharge.